

## Water Test Report

Despatch No. 1				Date -09.04.2024			
				Report No. 01 Date-09.04.2024			
A		Name and address		School of Excellence Imli Chouraha Ganjbasoda			
<b>2. Particulars of a sample place of collection &amp; Details</b>							
B	Reference No.	575/soe/sdws/2024-25					
3	Date And Time of sample	08.04.2024, 02:10 PM					
4	Date and analysis start	08.04.2024					
5	Date and analysis end	09.04.2024					
6	Unique ID	76					
7	Condition of the	Ok					
S.No.	Name of Parameter	Name of test methods used	BIS 10500-2012		Unit	Unique ID	
			Desireabl e limits	Permissi ble limits		76	
1	Tempratur e	Celcius			Degreec	32	
2	Turbidity	part 10	1	5	NTU	1.2	
3	Colour	part04	5	15	Hazon scale	-	
4	Taste	part7,8	Agreeable	not agreeable	none	Agreeable	
5	Odour	part03	Agreeable	not agreeable	none	Agreeable	
6	pH	part11	6.5-8.5	No relaxation	pHScale	7.6	
7	Conductiv ity	part16			micromho /cm	1177	
8	Total Solids	part16	500	2000	Mg/l	694	
9	Total Alkalinity	part23	200	600	Mg/l	136	
10	Total hardness as CaCO <sub>3</sub>	part21	200	600	Mg/l	374	
11	Ca as ca <sup>++</sup>	part40	75	200	Mg/l	12	
12	Mg as Mg <sup>++</sup>	part46	30	100	Mg/l	82.5	
13	Chloride	part32	250	1000	Mg/l	56.5	
14	Nitrate as No <sub>3</sub>	part34	45	45	Mg/l	1.2	
15	Iron	part53	0.3	0.3	Mg/l	0.1	
16	Fluoride	part60	1	1.5	Mg/l	0.6	
17	Sulphate	part24	300	400	Mg/l	-	
18	Magnese	part59	0.1	0.3	Mg/l	0.0	
19	Arsenic	part37	0.01	0.05	Mg/l	0.0	
20	Fecal conform	part10	0/100	0/100	per100ml	Nil	
21	Total Conform	part10	0/100	0/100	per100ml	Nil	

Note:- 1. Sample has been provided by the customer and sample tested as received.

*AD*  
Signature of analyst

Water testing laboratory Ganjbasoda (M.P)

*Faj Anjali SIE*

Amar Dahiya  
Authorised Signatory & Quality manager  
Water testing laboratory Ganjbasoda (M.P)

**कार्यालय**  
**स्वास्थ्य एवं**  
**शुद्धि एवं पर्यावरण विभाग**

**SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**


No.

Date: 2.4.2024

It is certified that an inspection team headed by Mr. Anjali Mabiya.....Designation Sub-Engineer.....  
Ganj Basoda, Distt. Vidisha (M.P.) inspected the **School of Excellence, Ahead Imli Chouraha, Laud Sahib Ki Bagiya, Behlot, Ganj Basoda, Distt. Vidisha (M.P.)** and found that the **School of Excellence** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of Two Years.

Anjali  
Signature with seal



Name Anjali Mabiya

Designation Sub-Engineer

To,

**School of Excellence,  
Ahead Imli Chouraha, Laud Sahib Ki Bagiya  
Behlot, Ganj Basoda, Distt. Vidisha (M.P.)**